



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Apr-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 24-Apr-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Apr-22	0:00:00	24-Apr-22	4:00:00	4:00:00	35.00	0.140	Today (i.e. 25.04.2022), 1 SSP-CHPH M/c is running at 10:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	24-Apr-22	21:45:00	24-Apr-22	24:00:00	2:15:00	35.00	0.076	
3	24-Apr-22	0:00:00	24-Apr-22	0:00:00	0:00:00	0.00	0.000	
4	24-Apr-22	0:00:00	24-Apr-22	0:00:00	0:00:00	0.00	0.000	
5	24-Apr-22	0:00:00	24-Apr-22	24:00:00	24:00:00	37.00	0.859	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Apr-22	14:30:00	24-Apr-22	17:15:00	2:45:00	171	0.468	Today (i.e. 25.04.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	24-Apr-22	14:15:00	24-Apr-22	17:00:00	2:45:00	168	0.468	
3	24-Apr-22	14:00:00	24-Apr-22	16:45:00	2:45:00	169	0.466	
4	24-Apr-22	0:00:00	24-Apr-22	2:00:00	2:00:00	170	0.342	
5	24-Apr-22	00:00 21:45	24-Apr-22	2:15 24:00	4:30:00	164	0.744	
6	24-Apr-22	22:15:00	24-Apr-22	24:00:00	1:45:00	170	0.300	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.075	2.788	3.863
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	20.201	57.882	78.083
PREVIOUS DAY ACTUAL RUNNING HOURS	30:15:00	16:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	16:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	16:15:00	

SSP hydrological data : at 08:00 Hrs on 25-Apr-22

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 120.77 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15518 Cusec 37.97 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11980 Cusec 29.31 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7507	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	7413	7327	4653	576	28.00



*(Signature)*  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil