



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Apr-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 26-Apr-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Apr-22	0:00:00	26-Apr-22	24:00:00	24:00:00	37.00	0.863	Today (i.e. 27.04.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	26-Apr-22	0:00:00	26-Apr-22	0:00:00	0:00:00	0.00	0.000	
3	26-Apr-22	0:00:00	26-Apr-22	0:00:00	0:00:00	0.00	0.000	
4	26-Apr-22	0:00:00	26-Apr-22	0:00:00	0:00:00	0.00	0.000	
5	26-Apr-22	0:00:00	26-Apr-22	0:00:00	0:00:00	37.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Apr-22	14:30:00	26-Apr-22	17:15:00	2:45:00	170	0.462	Today (i.e. 27.04.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	26-Apr-22	14:15:00	26-Apr-22	17:00:00	2:45:00	169	0.462	
3	26-Apr-22	14:00:00	26-Apr-22	16:45:00	2:45:00	169	0.466	
4	26-Apr-22	22:00:00	26-Apr-22	24:00:00	2:00:00	169	0.346	
5	26-Apr-22	00:00 22:15	26-Apr-22	2:00 24:00	3:45:00	169	0.636	
6	26-Apr-22	0:00:00	26-Apr-22	2:15:00	2:15:00	170	0.380	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.863	2.752	3.615
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	22.185	63.388	85.573
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	16:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	16:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	15:45:00	

SSP hydrological data : at 08:00 Hrs on 27-Apr-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6815 Cusec 16.67 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9943 Cusec 24.33 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6269	605

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	5216	5216	4727	574	29.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE
27/4/22

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil