



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-May-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-May-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-May-22	0:00 14:00	1-May-22	13:42 24:00	23:42:00	36.00	0.844	Today (i.e. 02.05.2022), 0 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	1-May-22	0:00:00	1-May-22	0:00:00	0:00:00	0.00	0.000	
3	1-May-22	0:00:00	1-May-22	0:00:00	0:00:00	0.00	0.000	
4	1-May-22	0:00:00	1-May-22	0:00:00	0:00:00	0.00	0.000	
5	1-May-22	0:00:00	1-May-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-May-22	14:45:00	1-May-22	17:30:00	2:45:00	171	0.470	Today (i.e. 02.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	1-May-22	14:30:00	1-May-22	17:15:00	2:45:00	170	0.466	
3	1-May-22	14:15:00	1-May-22	17:00:00	2:45:00	169	0.468	
4	1-May-22	0:00:00	1-May-22	1:45:00	1:45:00	169	0.298	
5	1-May-22	00:00 22:00	1-May-22	2:00 24:00	4:00:00	168	0.682	
6	1-May-22	22:15:00	1-May-22	24:00:00	1:45:00	170	0.296	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.844	2.680	3.524
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.844	2.680	3.524
PREVIOUS DAY ACTUAL RUNNING HOURS	23:42:00	15:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	15:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	15:45:00	

SSP hydrological data : at 08:00 Hrs on 2-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7384 Cusec 18.07 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8958 Cusec 21.92 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
4497	601

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
603	0	4537	4560	4398	647	29.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member (Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

Rajesh Sharma
21/5/22