



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-May-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 04-May-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-May-22	0:00:00	4-May-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 05.05.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	4-May-22	0:00:00	4-May-22	0:00:00	0:00:00	0.00	0.000	
3	4-May-22	0:00:00	4-May-22	0:00:00	0:00:00	0.00	0.000	
4	4-May-22	0:00:00	4-May-22	0:00:00	0:00:00	0.00	0.000	
5	4-May-22	0:00:00	4-May-22	24:00:00	24:00:00	38.00	0.879	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-May-22	14:00:00	4-May-22	17:15:00	3:15:00	170	0.548	Today (i.e. 05.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	4-May-22	14:15:00	4-May-22	17:30:00	3:15:00	169	0.546	
3	4-May-22	14:30:00	4-May-22	17:45:00	3:15:00	170	0.554	
4	4-May-22	0:00 21:45	4-May-22	3:00 24:00	5:15:00	169	0.898	
5	4-May-22	0:00 22:00	4-May-22	2:15 24:00	4:15:00	168	0.720	
6	4-May-22	0:00 23:15	4-May-22	2:30 24:00	3:15:00	169	0.548	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.879	3.814	4.693
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	3.252	12.424	15.676
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	22:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	22:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	21:15:00	

SSP hydrological data : at 08:00 Hrs on 5-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.57 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4172 Cusec 10.21 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11681 Cusec 28.58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4899	628

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	4864	5302	6379	636	28.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil