



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-May-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 11-May-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	11-May-22	16:30:00	11-May-22	24:00:00	7:30:00	37.00	0.270	Today (i.e. 12.05.2022), 1 SSP-CHPH M/c is running at 10:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	11-May-22	0:00:00	11-May-22	0:00:00	0:00:00	0.00	0.000	
3	11-May-22	0:00:00	11-May-22	0:00:00	0:00:00	0.00	0.000	
4	11-May-22	0:00:00	11-May-22	11:30:00	11:30:00	36.00	0.411	
5	11-May-22	0:00:00	11-May-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	11-May-22	14:30:00	11-May-22	17:30:00	3:00:00	168	0.504	Today (i.e. 12.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	11-May-22	14:45:00	11-May-22	17:45:00	3:00:00	168	0.504	
3	11-May-22	0:00:00	11-May-22	0:00:00	0:00:00	0	0.000	
4	11-May-22	00:00 21:30	11-May-22	1:45 24:00	4:15:00	170	0.720	
5	11-May-22	0:00 21:45	11-May-22	2:00 24:00	4:15:00	167	0.706	
6	11-May-22	0:00 23:00	11-May-22	2:30 24:00	3:30:00	169	0.588	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.681	3.022	3.703
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	8.424	36.936	45.360
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	18:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	16:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 12-May-22

DATA RECEIVED FROM FLOOD CELL


- RESERVOIR LEVEL IN Metres 120.04 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14499 Cusec 35.47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9168 Cusec 22.43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4297	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
621	0	4572	4209	4959	617	29.00



  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Detail:-

Nil