



नर्मदा विद्युत नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-May-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-May-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-May-22	0:00:00	12-May-22	24:00:00	24:00:00	37.00	0.849	Today (i.e. 13.05.2022), 0 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	12-May-22	0:00:00	12-May-22	0:00:00	0:00:00	0.00	0.000	
3	12-May-22	0:00:00	12-May-22	0:00:00	0:00:00	0.00	0.000	
4	12-May-22	0:00:00	12-May-22	0:00:00	0:00:00	0.00	0.000	
5	12-May-22	0:00:00	12-May-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-May-22	0:00:00	12-May-22	0:00:00	0:00:00	0	0.000	Today (i.e. 13.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	12-May-22	14:30:00	12-May-22	17:15:00	2:45:00	169	0.466	
3	12-May-22	14:45:00	12-May-22	17:30:00	2:45:00	169	0.464	
4	12-May-22	00:00 22:00	12-May-22	1:45 24:00	3:45:00	169	0.636	
5	12-May-22	00:00 22:15	12-May-22	2:00 24:00	3:45:00	167	0.628	
6	12-May-22	00:00 22:30	12-May-22	02:15 24:00	3:45:00	169	0.636	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.849	2.830	3.679
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.273	39.766	49.039
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	16:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	13:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 13-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.06 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12051 Cusec 29.48 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9951 Cusec 24.35 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4571	621

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	4618	5072	4879	618	29.00



(Signature)
13/5/22
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Detail:-

Nil