



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-May-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 16-May-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-May-22	0:00 13:00	16-May-22	7:00 24:00	18:00:00	36.00	0.634	Today (i.e. 17.05.2022), 0 SSP-CHPH M/c is running at 10:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	16-May-22	0:00:00	16-May-22	0:00:00	0:00:00	0.00	0.000	
3	16-May-22	0:00:00	16-May-22	0:00:00	0:00:00	0.00	0.000	
4	16-May-22	0:00:00	16-May-22	0:00:00	0:00:00	0.00	0.000	
5	16-May-22	0:00:00	16-May-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-May-22	15:00:00	16-May-22	18:00:00	3:00:00	170	0.508	Today (i.e. 17.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	16-May-22	0:00:00	16-May-22	0:00:00	0:00:00	0	0.000	
3	16-May-22	0:00:00	16-May-22	0:00:00	0:00:00	0	0.000	
4	16-May-22	0:00:00 21:45:00	16-May-22	1:45:00 24:00:00	4:00:00	168	0.682	
5	16-May-22	0:00:00 22:00:00	16-May-22	2:00:00 24:00:00	4:00:00	168	0.682	
6	16-May-22	0:00:00 23:15:00	16-May-22	2:15:00 24:00:00	3:00:00	169	0.506	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.634	2.378	3.012
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	12.124	49.202	61.326
PREVIOUS DAY ACTUAL RUNNING HOURS	18:00:00	14:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	20:00:00	14:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 17-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.85 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4287 Cusec 10.49 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7176 Cusec 17.56 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4645	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
628	0	4587	3207	3969	615	29.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil