



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-May-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 22-May-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-May-22	0:00:00	22-May-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 23.05.2022), 0 SSP-CHPH M/c is running at 10:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	22-May-22	0:00:00	22-May-22	0:00:00	0:00:00	0.00	0.000	
3	22-May-22	0:00:00	22-May-22	0:00:00	0:00:00	0.00	0.000	
4	22-May-22	0:00:00	22-May-22	0:00:00	0:00:00	0.00	0.000	
5	22-May-22	7:00:00	22-May-22	22:00:00	15:00:00	36.00	0.503	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-May-22	0:00:00	22-May-22	0:00:00	0:00:00	0	0.000	Today (i.e. 23.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	22-May-22	0:00:00	22-May-22	0:00:00	0:00:00	0	0.000	
3	22-May-22	15:00:00	22-May-22	18:00:00	3:00:00	169	0.504	
4	22-May-22	00:00 21:45	22-May-22	1:45 24:00	4:00:00	170	0.686	
5	22-May-22	0:00:00 22:00:00	22-May-22	2:00:00 24:00:00	4:00:00	165	0.664	
6	22-May-22	0:00:00 23:15:00	22-May-22	2:15:00 24:00:00	3:00:00	168	0.506	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.503	2.360	2.863
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	16.093	63.406	79.499
PREVIOUS DAY ACTUAL RUNNING HOURS	15:00:00	14:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	14:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 23-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.62 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6026 Cusec 14.74 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7167 Cusec 17.53 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3569	615

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	3087	3062	4105	610	29.00



*(Signature)*  
23/5/22  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE (E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil