



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-May-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 23-May-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-May-22	0:00:00	23-May-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 24.05.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	23-May-22	0:00:00	23-May-22	0:00:00	0:00:00	0.00	0.000	
3	23-May-22	0:00:00	23-May-22	0:00:00	0:00:00	0.00	0.000	
4	23-May-22	0:00:00	23-May-22	0:00:00	0:00:00	0.00	0.000	
5	23-May-22	11:30:00	23-May-22	24:00:00	12:30:00	35.00	0.413	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-May-22	15:00:00	23-May-22	18:00:00	3:00:00	170	0.510	Today (i.e. 24.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	23-May-22	0:00:00	23-May-22	0:00:00	0:00:00	0	0.000	
3	23-May-22	23:15:00	23-May-22	24:00:00	0:45:00	169	0.134	
4	23-May-22	00:00 21:45	23-May-22	1:45 24:00	4:00:00	170	0.682	
5	23-May-22	0:00:00	23-May-22	2:00:00	2:00:00	165	0.330	
6	23-May-22	0:00:00 22:00:00	23-May-22	2:15:00 24:00:00	4:15:00	170	0.716	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.413	2.372	2.785
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	16.506	65.778	82.284
PREVIOUS DAY ACTUAL RUNNING HOURS	12:30:00	14:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	19:00:00	14:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 24-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.52 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1989 Cusec 4.87 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7219 Cusec 17.66 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3087	615

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
621	0	3476	3153	4066	608	28.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Kasor, Dhule-1, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil