



नर्मदा विद्युत नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-May-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 25-May-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-May-22	0:00:00	25-May-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 26.05.2022), 1 SSP-CHPH M/c is running at 10:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	25-May-22	0:00:00	25-May-22	0:00:00	0:00:00	0.00	0.000	
3	25-May-22	0:00:00	25-May-22	0:00:00	0:00:00	0.00	0.000	
4	25-May-22	0:00:00	25-May-22	0:00:00	0:00:00	0.00	0.000	
5	25-May-22	0:00 7:15	25-May-22	2:00 24:00	18:45:00	35.00	0.650	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-May-22	15:00:00	25-May-22	18:00:00	3:00:00	171	0.512	Today (i.e. 26.05.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	25-May-22	0:00:00	25-May-22	0:00:00	0:00:00	0	0.000	
3	25-May-22	0:00:00	25-May-22	0:00:00	0:00:00	0	0.000	
4	25-May-22	0:00:00 21:45:00	25-May-22	1:45 24:00	4:00:00	170	0.684	
5	25-May-22	0:00 22:00	25-May-22	2:00 24:00	4:00:00	168	0.670	
6	25-May-22	0:00:00 23:15:00	25-May-22	2:15:00 24:00:00	3:00:00	171	0.514	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.650	2.380	3.030
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	17.796	70.534	88.330
PREVIOUS DAY ACTUAL RUNNING HOURS	18:45:00	14:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	14:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 26-May-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2874 Cusec 7.03 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9276 Cusec 26.69 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4070	619

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	4503	5210	4066	605	28.00



*(Signature)*  
(Rajesh Sharma) 26/5/22  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil