



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Jun-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Jun-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Jun-22	20:30:00	5-Jun-22	24:00:00	3:30:00	31.00	0.111	Today (i.e. 06.06.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	5-Jun-22	0:00:00	5-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	5-Jun-22	0:00:00	5-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	5-Jun-22	0:00:00	5-Jun-22	24:00:00	24:00:00	32.00	0.752	
5	5-Jun-22	0:00:00	5-Jun-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Jun-22	00:00 18:30	5-Jun-22	01:30 24:00	7:00:00	168	1.162	Today (i.e. 06.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	5-Jun-22	00:00 18:45	5-Jun-22	01:45 24:00	7:00:00	167	1.152	
3	5-Jun-22	19:45:00	5-Jun-22	24:00:00	4:15:00	160	0.668	
4	5-Jun-22	00:00 20:30	5-Jun-22	02:00 24:00	5:30:00	168	0.918	
5	5-Jun-22	0:00:00	5-Jun-22	2:15:00	2:15:00	158	0.354	
6	5-Jun-22	00:00 20:45	5-Jun-22	02:30 24:00	5:45:00	168	0.950	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.863	5.204	6.067
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.630	23.184	27.814
PREVIOUS DAY ACTUAL RUNNING HOURS	27:30:00	31:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	32:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	30:30:00	

SSP hydrological data : at 08:00 Hrs on 6-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.72 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6157 Cusec 15.06 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15133 Cusec 37.02 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6116	617

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	6065	9180	5953	366	28.00



for share
6/6/22
JE, ETC, NCA

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. 220kV Bus Bar Protection under Outage for commissioning of New Bus bar protection panel for 220kV Bus of CHPH.

3. SCO Mode Detail:-

Nil