



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Jun-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 06-Jun-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Jun-22	0:00 18:25	6-Jun-22	0:30 24:00	6:05:00	32.00	0.192	Today (i.e. 07.06.2022), 2 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	6-Jun-22	0:00:00	6-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	6-Jun-22	0:00:00	6-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	6-Jun-22	0:00:00	6-Jun-22	18:30:00	18:30:00	32.00	0.574	
5	6-Jun-22	0:00:00	6-Jun-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Jun-22	0:00:00	6-Jun-22	1:30:00	1:30:00	167	0.250	Today (i.e. 07.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	6-Jun-22	00:00 18:30	6-Jun-22	01:45 24:00	7:15:00	168	1.198	
3	6-Jun-22	00:00 18:45	6-Jun-22	2:00 24:00	7:15:00	163	1.146	
4	6-Jun-22	00:00 19:00	6-Jun-22	02:15 24:00	7:15:00	168	1.204	
5	6-Jun-22	21:15:00	6-Jun-22	24:00:00	2:45:00	158	0.440	
6	6-Jun-22	00:00 20:15	6-Jun-22	02:30 24:00	6:15:00	168	1.040	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.766	5.278	6.044
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	5.396	28.462	33.858
PREVIOUS DAY ACTUAL RUNNING HOURS	24:35:00	32:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	41:00:00	30:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	30:30:00	

SSP hydrological data : at 08:00 Hrs on 7-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.53 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3920 Cusec 9.59 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14649 Cusec 35.84 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6065	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	6050	5251	9398	364	29.00



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. 220kV Bus Bar Protection system under Outage for commissioning of New Bus bar protection panel.

3. SCO Mode Detail:-

Nil

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Tanuj A W
27/06/22
JELCME (NCA)