



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Jun-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 08-Jun-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Jun-22	0:00:00	8-Jun-22	19:00:00	19:00:00	31.00	0.588	<i>Today (i.e. 09.06.2022), 1 SSP-CHPH M/c is running at 10:00 hrs.</i>  <i>CHPH Unit no. 3 is under COH from 01.04.2022.</i>
2	8-Jun-22	0:00:00	8-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	8-Jun-22	0:00:00	8-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	8-Jun-22	12:30:00	8-Jun-22	24:00:00	11:30:00	31.00	0.352	
5	8-Jun-22	0:00:00	8-Jun-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Jun-22	0:00 18:45	8-Jun-22	1:30 24:00	6:45:00	165	1.110	<i>Today (i.e. 09.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.</i>
2	8-Jun-22	0:00 19:00	8-Jun-22	1:45 24:00	6:45:00	164	1.104	
3	8-Jun-22	00:00 18:30	8-Jun-22	2:00 24:00	7:30:00	161	1.194	
4	8-Jun-22	0:00:00	8-Jun-22	2:15:00	2:15:00	164	0.366	
5	8-Jun-22	21:30:00	8-Jun-22	24:00:00	2:30:00	161	0.408	
6	8-Jun-22	0:00 21:45	8-Jun-22	2:30 24:00	4:45:00	168	0.796	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.940	4.978	5.918
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	7.266	38.428	45.694
PREVIOUS DAY ACTUAL RUNNING HOURS	30:30:00	30:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	30:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	30:45:00	

SSP hydrological data : at 08:00 Hrs on 9-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.05 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1503 Cusec 3.68 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15156 Cusec 37.08 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6045	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
621	0	6076	6491	8665	358	28.00



*(Signature)*  
9/6/22  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil