



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Jun-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 09-Jun-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|----------|----------|----------|-------------|----------------|-------------------|-----------------------------------------------------------------------------------------------------------------------|
| 1 | 9-Jun-22 | 18:45:00 | 9-Jun-22 | 24:00:00 | 5:15:00 | 30.00 | 0.157 | Today (i.e. 10.06.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022. |
| 2 | 9-Jun-22 | 0:00:00 | 9-Jun-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 9-Jun-22 | 0:00:00 | 9-Jun-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 9-Jun-22 | 0:00:00 | 9-Jun-22 | 24:00:00 | 24:00:00 | 31.00 | 0.730 | |
| 5 | 9-Jun-22 | 0:00:00 | 9-Jun-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|----------------|----------|----------------|-------------|----------------|-------------------|------------------------------------------------------------------|
| 1 | 9-Jun-22 | 00:00 18:30 | 9-Jun-22 | 01:45 24:00 | 7:15:00 | 165 | 1.180 | Today (i.e. 10.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs. |
| 2 | 9-Jun-22 | 00:00 18:45 | 9-Jun-22 | 02:00 24:00 | 7:15:00 | 163 | 1.172 | |
| 3 | 9-Jun-22 | 0:00:00 | 9-Jun-22 | 1:30:00 | 1:30:00 | 161 | 0.232 | |
| 4 | 9-Jun-22 | 21:30:00 | 9-Jun-22 | 24:00:00 | 2:30:00 | 164 | 0.412 | |
| 5 | 9-Jun-22 | 00:00 21:45 | 9-Jun-22 | 02:15 24:00 | 4:30:00 | 161 | 0.722 | |
| 6 | 9-Jun-22 | 00:00 19:05 | 9-Jun-22 | 02:30 24:00 | 7:25:00 | 166 | 1.206 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|------------------------------------------|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 0.887 | 4.924 | 5.811 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 8.153 | 43.352 | 51.505 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 29:15:00 | 30:25:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00 | 30:45:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 29:30:00 | |

SSP hydrological data : at 08:00 Hrs on 10-Jun-22

DATA RECEIVED FROM FLOOD CELL


- RESERVOIR LEVEL IN Metres 116.80 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 504 Cusec 1.23 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14744 Cusec 36.07 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 6075 | 621 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|------|------|------|----------|----------|
| 617 | 0 | 6103 | 6048 | 8696 | 355 | 28.00 |




(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil