



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Jun-22
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Jun-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Jun-22	0:00:00	11-Jun-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 12.06.2022), 1 SSP-CHPH M/c is running at 10:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	11-Jun-22	0:00:00	11-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	11-Jun-22	0:00:00	11-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	11-Jun-22	0:00:00	11-Jun-22	24:00:00	24:00:00	30.00	0.719	
5	11-Jun-22	0:00:00	11-Jun-22	0:00:00	0:00:00	0.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Jun-22	0:00 21:45	11-Jun-22	2:30 24:00	4:45:00	162	0.752	Today (i.e. 12.06.2022), 0 SSP-RBPB M/c is running at 10:00 hrs.
2	11-Jun-22	0:00 18:45	11-Jun-22	2:15 24:00	7:30:00	161	1.188	
3	11-Jun-22	0:00 19:00	11-Jun-22	1:45 24:00	6:45:00	155	1.028	
4	11-Jun-22	0:00:00	11-Jun-22	1:30:00	1:30:00	157	0.234	
5	11-Jun-22	22:30:00	11-Jun-22	24:00:00	1:30:00	151	0.228	
6	11-Jun-22	0:00 19:15	11-Jun-22	2:45 24:00	7:30:00	164	1.208	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.719	4.638	5.357
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.582	52.916	62.498
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	29:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	28:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	27:30:00	

SSP hydrological data : at 08:00 Hrs on 12-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.46 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1821 Cusec 4.46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13148 Cusec 32.17 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5370	623

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
624	0	5402	5068	8080	350	28.00



Rajesh Sharma
J. E. (Elect),
EMC, NCA

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Detail:-

Nil

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE