



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Jun-22  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 12-Jun-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Jun-22	17:30:00	12-Jun-22	21:18:00	3:48:00	29.00	0.110	Today (i.e. 13.06.2022), 1 SSP-CHPH M/c is running at 10:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	12-Jun-22	0:00:00	12-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	12-Jun-22	0:00:00	12-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	12-Jun-22	0:00:00	12-Jun-22	12:00:00	12:00:00	30.00	0.347	
5	12-Jun-22	21:43:00	12-Jun-22	24:00:00	2:17:00	30.00	0.067	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Jun-22	0:00 21:15	12-Jun-22	1:45 24:00	4:30:00	162	0.714	Today (i.e. 13.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	12-Jun-22	0:00 19:00	12-Jun-22	2:00 24:00	7:00:00	164	1.120	
3	12-Jun-22	0:00 19:15	12-Jun-22	2:15 24:00	7:00:00	156	1.066	
4	12-Jun-22	0:00:00	12-Jun-22	0:00:00	0:00:00	0	0.000	
5	12-Jun-22	0:00:00 22:30:00	12-Jun-22	2:30:00 24:00:00	4:00:00	153	0.606	
6	12-Jun-22	0:00 19:30	12-Jun-22	1:30 24:00	6:00:00	164	0.970	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.524	4.476	5.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	10.106	57.392	67.498
PREVIOUS DAY ACTUAL RUNNING HOURS	18:05:00	28:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	27:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	27:30:00	

SSP hydrological data : at 08:00 Hrs on 13-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.46 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11718 Cusec 28.67 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11368 Cusec 27.81 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5402	624

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
619	0	4823	3692	7676	349	28.00



*(Signature)*  
13/06

( Hemant Pandey )  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj and Kasor lines are in service.

2. SCO Mode Detail:-

Nil