नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Jun-22
ISSUE TIME: 10:00 Hrs
FOR DATE : 19-Jun-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Jun-22	0:00:00	19-Jun-22	12:30:00	12:30:00	28.00	0.329	
2	19-Jun-22	0:00:00	19-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	19-Jun-22	0:00:00	19-Jun-22	0:00:00	0:00:00	0.00	0.000	*Today (i.e. 20.06.2022), 1 SSP-CHPH M/C is running at 10:00 hrs.*
4	19-Jun-22	17:30:00	19-Jun-22	24:00:00	6:30:00	27.00	0.170	*CHPH Unit no. 3 is under COH from 01.04.2022.*
5	19-Jun-22	0:00:00	19-Jun-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Jun-22	0:00 5:15 21:15	19-Jun-22	1:45 7:45 24:00	7:00:00	158	1.104	
2	19-Jun-22	0:00 22:45	19-Jun-22	1:30 24:00	2:45:00	155	0.412	
3	19-Jun-22	0:00:00	19-Jun-22	2:00:00	2:00:00	157	0.306	
4	19-Jun-22	0:00:00	19-Jun-22	2:15:00	2:15:00	155	0.348	*Today (i.e. 20.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.*
5	19-Jun-22	18:45:00	19-Jun-22	24:00:00	5:15:00	158	0.826	
6	19-Jun-22	0:00 19:00	19-Jun-22	2:30 24:00	7:30:00	162	1.186	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.499	4.182	4.681
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	14.343	88.030	102.373
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	26:45:00	
TODAY's DC (Schedule) Planned (in Hours)	24:00:00	26:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	28:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.38 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3084 Cusec 7.55 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10921 Cusec 26.72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4062	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	4020	3776	7145	336	30.00

20/6/22

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Detail:-
Unit No.1: 3:25 Hrs on 20.06.2022 to 05:50 Hrs on 20.06.2022.
Unit No.2: 3:35 Hrs on 20.06.2022 to 05:55 Hrs on 20.06.2022.