



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Jun-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 22-Jun-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Jun-22	0:00:00	22-Jun-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 23.06.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	22-Jun-22	0:00:00	22-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	22-Jun-22	0:00:00	22-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	22-Jun-22	0:00:00	22-Jun-22	0:00:00	0:00:00	0.00	0.000	
5	22-Jun-22	0:00:00 7:00	22-Jun-22	2:00 24:00	19:00:00	27.00	0.479	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Jun-22	4:30 22:45	22-Jun-22	6:45 24:00	3:30:00	159	0.554	Today (i.e. 23.06.2022), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	22-Jun-22	0:00 18:30	22-Jun-22	1:30 24:00	7:00:00	157	1.090	
3	22-Jun-22	0:00 18:45	22-Jun-22	1:45 24:00	7:00:00	154	1.064	
4	22-Jun-22	0:00 22:15	22-Jun-22	2:00 24:00	3:45:00	160	0.592	
5	22-Jun-22	0:00:00	22-Jun-22	2:15:00	2:15:00	155	0.346	
6	22-Jun-22	0:00 22:30	22-Jun-22	2:30 24:00	4:00:00	161	0.632	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.479	4.278	4.757
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	15.703	100.836	116.539
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	27:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	28:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	27:15:00	

SSP hydrological data : at 08:00 Hrs on 23-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.08 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7509 Cusec 18.37 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11847 Cusec 28.98 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4043	608

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
624	0	4550	4620	7227	332	30.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil.