



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Jun-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 28-Jun-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	28-Jun-22	0:00:00	28-Jun-22	24:00:00	24:00:00	25.00	0.579	Today (i.e. 29.06.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	28-Jun-22	0:00:00	28-Jun-22	0:00:00	0:00:00	0.00	0.000	
3	28-Jun-22	0:00:00	28-Jun-22	0:00:00	0:00:00	0.00	0.000	
4	28-Jun-22	0:00:00	28-Jun-22	0:00:00	0:00:00	0.00	0.000	
5	28-Jun-22	19:00:00	28-Jun-22	23:00:00	4:00:00	25.00	0.095	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	28-Jun-22	0:00 18:45	28-Jun-22	1:45 24:00	7:00:00	159	1.082	Today (i.e. 29.06.2022), 0 SSP-RBPB M/c is running at 9:00 hrs.
2	28-Jun-22	0:00 19:15	28-Jun-22	7:00 24:00	11:45:00	155	1.768	
3	28-Jun-22	0:00 19:00	28-Jun-22	1:30 24:00	6:30:00	153	0.964	
4	28-Jun-22	0:00 19:45	28-Jun-22	1:15 24:00	5:30:00	153	0.828	
5	28-Jun-22	0:00:00	28-Jun-22	1:00:00	1:00:00	148	0.152	
6	28-Jun-22	18:30:00	28-Jun-22	24:00:00	5:30:00	161	0.860	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.674	5.654	6.328
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.428	126.408	145.836
PREVIOUS DAY ACTUAL RUNNING HOURS	28:00:00	37:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	7:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Jun-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8930 Cusec 21.85 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14438 Cusec 35.32 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
5370	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
630	0	5742	5305	9133	330	30.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil.