



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Jun-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 29-Jun-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 29-Jun-22 | 0:00:00 | 29-Jun-22 | 24:00:00 | 24:00:00 | 24.00 | 0.578 | Today (i.e. 30.06.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022. |
| 2 | 29-Jun-22 | 22:00:00 | 29-Jun-22 | 24:00:00 | 2:00:00 | 0.00 | 0.048 | |
| 3 | 29-Jun-22 | 0:00:00 | 29-Jun-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 29-Jun-22 | 18:00:00 | 29-Jun-22 | 24:00:00 | 6:00:00 | 25.00 | 0.150 | |
| 5 | 29-Jun-22 | 14:30:00 | 29-Jun-22 | 24:00:00 | 9:30:00 | 24.00 | 0.219 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------------|-----------|---------------|-------------|----------------|-------------------|---|
| 1 | 29-Jun-22 | 0:00 19:00 | 29-Jun-22 | 1:00 24:00 | 6:00:00 | 155 | 0.912 | Today (i.e. 30.06.2022), 0 SSP-RBPH M/c is running at 9:00 hrs. |
| 2 | 29-Jun-22 | 0:00 19:15 | 29-Jun-22 | 1:15 24:00 | 6:00:00 | 152 | 0.904 | |
| 3 | 29-Jun-22 | 0:00 19:30 | 29-Jun-22 | 1:30 24:00 | 6:00:00 | 149 | 0.878 | |
| 4 | 29-Jun-22 | 0:00 19:45 | 29-Jun-22 | 1:45 24:00 | 6:00:00 | 155 | 0.916 | |
| 5 | 29-Jun-22 | 0:00:00 | 29-Jun-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 29-Jun-22 | 0:00 20:00 | 29-Jun-22 | 2:00 24:00 | 6:00:00 | 157 | 0.922 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 0.995 | 4.532 | 5.527 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 20.423 | 130.940 | 151.363 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 41:30:00 | 30:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 71:00:00 | 22:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 72:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 30-Jun-22

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 114.67 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6522 Cusec 15.96 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18454 Cusec 45.15 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 5742 | 630 |

AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|-------|-------|------|----------|----------|
| 623 | 0 | 12130 | 10587 | 7867 | 328 | 30.00 |



(Signature)
30/6/22
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Detail:-
Nil.