



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 01-Jul-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|----------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 2:00:00 | 2:00:00 | 23.00 | 0.045 | Today (i.e. 02.07.2022), 1 SSP-CHPH M/C is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022. |
| 2 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 24:00:00 | 24:00:00 | 24.00 | 0.556 | |
| 3 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 24:00:00 | 24:00:00 | 24.00 | 0.552 | |
| 5 | 1-Jul-22 | 14:30:00 | 1-Jul-22 | 18:00:00 | 3:30:00 | 23.00 | 0.077 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today (i.e. 02.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs. |
| 2 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 1-Jul-22 | 0:00:00 | 1-Jul-22 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 1.230 | 0.000 | 1.230 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 1.230 | 0.000 | 1.230 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 53:30:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 48:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 72:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 2-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4847 Cusec 11.86 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 9367 Cusec 22.92 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 15322 | 633 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|------|------|------|----------|----------|
| 618 | 0 | 9559 | 9367 | 0 | 150 | 30.00 |



For *Archita Koushik*
J.E. (EMC)
2-7-22
JEMC

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydrogmet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.2: 18:45 Hrs on 01.07.2022 to 06:55 Hrs on 02.07.2022.

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE