



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 04-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jul-22	18:00:00	4-Jul-22	21:30:00	3:30:00	22.00	0.078	Today (i.e. 05.07.2022), 2 SSP-CHPH M/Cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	4-Jul-22	0:00:00	4-Jul-22	24:00:00	24:00:00	22.00	0.522	
3	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	4-Jul-22	0:00:00	4-Jul-22	2:30:00	2:30:00	22.00	0.055	
5	4-Jul-22	5:00:00	4-Jul-22	24:00:00	19:00:00	22.00	0.408	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0	0.000	Today (i.e. 05.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs.
2	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0	0.000	
3	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0	0.000	
4	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0	0.000	
5	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0	0.000	
6	4-Jul-22	0:00:00	4-Jul-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.063	0.000	1.063
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.537	0.000	4.537
PREVIOUS DAY ACTUAL RUNNING HOURS	49:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	46:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.13 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2268 Cusec 5.55 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8542 Cusec 20.90 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9061	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	8090	8542	0	148	30.00



(Signature)
(Hemant Pandey)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

NIL