



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 07-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jul-22	17:30:00	7-Jul-22	23:30:00	6:00:00	22.00	0.134	Today (i.e. 08.07.2022), 2 SSP-CHPH M/Cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	7-Jul-22	0:00:00	7-Jul-22	24:00:00	24:00:00	23.00	0.532	
3	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	7-Jul-22	5:00:00	7-Jul-22	9:30:00	4:30:00	23.00	0.098	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0	0.000	Today (i.e. 08.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs.
2	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0	0.000	
3	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0	0.000	
4	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0	0.000	
5	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0	0.000	
6	7-Jul-22	0:00:00	7-Jul-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.764	0.000	0.764
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	6.905	0.000	6.905
PREVIOUS DAY ACTUAL RUNNING HOURS	34:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	27:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Jul-22

DATA RECEIVED FROM FLOOD CELL

· RESERVOIR LEVEL IN Metres	114.38 Mtrs.	
· AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	13560 Cusec	33.18 MCM
· AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	5821 Cusec	14.24 MCM
· GOG WATER REQUIREMENT(Next Day) in Cusec		

HR	GODBOLE
5559	619

· AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	5582	5821	0	149	30.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.2: 2:15 Hrs on 08.07.2022 to 06:05 Hrs on 08.07.2022.

Unit No.5: 2:25 Hrs on 08.07.2022 to 06:10 Hrs on 08.07.2022.

(Handwritten Signature)
8/7/22