



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 08-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Jul-22	6:30 18:00	8-Jul-22	10:00 20:30	6:00:00	23.00	0.135	Today (i.e. 09.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	8-Jul-22	0:00:00	8-Jul-22	24:00:00	24:00:00	23.00	0.528	
3	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0	0.000	Today (i.e. 09.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs.
2	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0	0.000	
3	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0	0.000	
4	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0	0.000	
5	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0	0.000	
6	8-Jul-22	0:00:00	8-Jul-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.663	0.000	0.663
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	7.568	0.000	7.568
PREVIOUS DAY ACTUAL RUNNING HOURS	30:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	17:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.52 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12297 Cusec 30.09 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3973 Cusec 9.72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5582	622

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	4305	3973	0	150	30.00



For
Rajesh Sharma
J. E. (Elect.)
EMC, NCA

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No.1: 00:55 Hrs on 09.07.2022 to 06:30 Hrs on 09.07.2022.

Unit No.6: 00:45 Hrs on 09.07.2022 to 06:35 Hrs on 09.07.2022.

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE