



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Jul-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 12-Jul-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Jul-22	18:00:00	12-Jul-22	24:00:00	6:00:00	26.00	0.154	Today (i.e. 13.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	12-Jul-22	0:00:00	12-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	12-Jul-22	0:00:00	12-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	12-Jul-22	0:00:00	12-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	12-Jul-22	0:00:00	12-Jul-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Jul-22	4:30 20:45	12-Jul-22	7:30 24:00	6:15:00	159	0.978	Today (i.e. 13.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs.
2	12-Jul-22	0:00 18:30	12-Jul-22	2:00 23:00	6:30:00	157	1.024	
3	12-Jul-22	0:00 18:45	12-Jul-22	2:15 20:35	4:05:00	157	0.624	
4	12-Jul-22	0:00 19:00	12-Jul-22	1:15 24:00	6:15:00	160	0.988	
5	12-Jul-22	0:00 19:15	12-Jul-22	1:30:00 24:00:00	6:15:00	155	0.970	
6	12-Jul-22	0:00 19:30	12-Jul-22	1:45 24:00	6:15:00	162	0.994	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.154	5.578	5.732
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	8.511	6.746	15.257
PREVIOUS DAY ACTUAL RUNNING HOURS	6:00:00	35:35:00	
TODAY'S DC (Schedule) Planned (in Hours)	19:00:00	31:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	31:30:00	

SSP hydrological data : at 08:00 Hrs on 13-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 117.36 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 22798 Cusec 55.78 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11539 Cusec 28.23 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3746	626

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
621	0	2405	1552	9987	166	30.00



*(Signature)*  
(Rajesh Sharma)  
13/7/22  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

- 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
- 400kV SSP-Dhule-2 line is ready.

3. SCO Mode Detail:-

Unit No. 2: 2:30 Hrs on 13.07.2022 to 07:00 Hrs on 13.07.2022.

Unit No. 3: 2:40 Hrs on 13.07.2022 to 07:05 Hrs on 13.07.2022.

Unit No. 5: 2:40 Hrs on 13.07.2022 to 07:10 Hrs on 13.07.2022.