



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-Jul-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 16-Jul-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	16-Jul-22	0:00:00	16-Jul-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 17.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	16-Jul-22	0:00:00	16-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	16-Jul-22	0:00:00	16-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	16-Jul-22	0:00:00	16-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	16-Jul-22	8:00 18:00	16-Jul-22	12:00 24:00	10:00:00	31.00	0.298	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN Mus	REMARKS
1	16-Jul-22	0:00:00	16-Jul-22	1:15:00	1:15:00	171	0.216	Today (i.e. 17.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs.
2	16-Jul-22	0:00 18:00	16-Jul-22	1:30 21:45	5:15:00	170	0.894	
3	16-Jul-22	18:15:00	16-Jul-22	24:00:00	5:45:00	175	0.980	
4	16-Jul-22	4:30 18:45	16-Jul-22	7:00 24:00	7:45:00	174	1.336	
5	16-Jul-22	0:00 19:15	16-Jul-22	1:45 24:00	6:30:00	175	1.124	
6	16-Jul-22	0:00 19:30	16-Jul-22	2:00 24:00	6:30:00	174	1.110	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.298	5.660	5.958
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.806	26.666	36.472
PREVIOUS DAY ACTUAL RUNNING HOURS	10:00:00	33:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	17:00:00	31:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	31:30:00	

SSP hydrological data : at 08:00 Hrs on 17-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.76 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 49929 Cusec 122.15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11218 Cusec 27.45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2486	616

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	2486	2007	9211	178	23.00



*Handwritten signature: Rajesh Sharma*  
*Handwritten text: To be checked, NCA*

100

(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 1: 01:20 Hrs on 17.07.2022 to 06:35 Hrs on 17.07.2022.

Unit No. 2: 01:30 Hrs on 17.07.2022 to 07:05 Hrs on 17.07.2022.