



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 19-Jul-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 18-Jul-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Jul-22	0:00:00	18-Jul-22	3:30:00	3:30:00	30.00	0.106	Today (i.e. 19.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	18-Jul-22	0:00:00	18-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	18-Jul-22	0:00:00	18-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	18-Jul-22	0:00:00	18-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	18-Jul-22	7:00:00	18-Jul-22	24:00:00	17:00:00	31.00	0.545	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Jul-22	0:00:00	18-Jul-22	1:30:00	1:30:00	186	0.286	Today (i.e. 19.07.2022), 0 SSP-RBPH M/c is running at 9:00 hrs.
2	18-Jul-22	0:00 18:00	18-Jul-22	1:45 22:15	6:00:00	189	1.124	
3	18-Jul-22	0:00 18:15	18-Jul-22	2:00 24:00	7:45:00	189	1.446	
4	18-Jul-22	0:00 18:30	18-Jul-22	2:15:00 24:00:00	7:45:00	189	1.456	
5	18-Jul-22	19:00:00	18-Jul-22	24:00:00	5:00:00	186	0.940	
6	18-Jul-22	19:00:00	18-Jul-22	24:00:00	5:00:00	190	0.930	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.651	6.182	6.833
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.977	38.442	49.419
PREVIOUS DAY ACTUAL RUNNING HOURS	20:30:00	33:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	22:30:00	33:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	31:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.52 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 36475 Cusec 89.24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14076 Cusec 34.44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3958	620

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	4654	4193	9883	185	21.00



*(Signature)*  
19/7/22  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kv SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 1: 02:30 Hrs on 19.07.2022 to 06:30 Hrs on 19.07.2022.

Unit No. 2: 02:40 Hrs on 19.07.2022 to 06:35 Hrs on 19.07.2022.