



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 19-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Jul-22	7:00:00	19-Jul-22	24:00:00	17:00:00	36.00	0.584	Today (i.e. 20.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	19-Jul-22	0:00:00	19-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	19-Jul-22	0:00:00	19-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	19-Jul-22	0:00:00	19-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	19-Jul-22	0:00:00	19-Jul-22	5:00:00	5:00:00	32.00	0.153	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Jul-22	17:45:00	19-Jul-22	24:00:00	6:15:00	188	1.162	Today (i.e. 20.07.2022), 2 SSP-RBPH M/cs are running at 9:00 hrs.
2	19-Jul-22	18:00:00	19-Jul-22	24:00:00	6:00:00	188	1.124	
3	19-Jul-22	0:00 18:15	19-Jul-22	1:30 24:00	7:15:00	189	1.358	
4	19-Jul-22	0:00 19:55	19-Jul-22	1:45:00 24:00:00	5:50:00	188	1.096	
5	19-Jul-22	0:00:00	19-Jul-22	2:00:00	2:00:00	188	0.382	
6	19-Jul-22	0:00:00	19-Jul-22	2:15:00	2:15:00	189	0.432	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.737	5.554	6.291
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	11.714	43.996	55.710
PREVIOUS DAY ACTUAL RUNNING HOURS	22:00:00	29:35:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	63:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.71 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 105165 Cusec ✓ 257.29 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16853 Cusec ✓ 41.23 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec ✓

HR	GODBOLE
4654	615

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	4654	5074	11779	192	0.88



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE (E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 5: 00:30 Hrs on 20.07.2022 to 06:45 Hrs on 20.07.2022.

Unit No. 6: 00:40 Hrs on 20.07.2022 to 06:50 Hrs on 20.07.2022.