



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 22-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Jul-22	6:30 18:30	22-Jul-22	13:30 24:00	12:30:00	39.00	0.487	Today (i.e. 23.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	22-Jul-22	0:00:00	22-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	22-Jul-22	0:00:00	22-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	22-Jul-22	0:00:00	22-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	22-Jul-22	0:00:00	22-Jul-22	2:00:00	2:00:00	36.00	0.071	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Jul-22	0:00:00	22-Jul-22	24:00:00	24:00:00	178	4.130	Today (i.e. 23.07.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	22-Jul-22	0:00:00	22-Jul-22	24:00:00	24:00:00	177	4.108	
3	22-Jul-22	0:00:00	22-Jul-22	24:00:00	24:00:00	178	4.144	
4	22-Jul-22	0:00:00	22-Jul-22	24:00:00	24:00:00	177	4.148	
5	22-Jul-22	0:00:00	22-Jul-22	24:00:00	24:00:00	175	4.142	
6	22-Jul-22	0:00:00	22-Jul-22	24:00:00	24:00:00	178	4.138	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.558	24.810	25.368
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	13.562	107.018	120.580
PREVIOUS DAY ACTUAL RUNNING HOURS	14:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	4:30:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 81158 Cusec 198.56 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 45403 Cusec 111.08 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3286	622

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
613	0	2838	2813	42590	211	32.00



For **Rajesh Sharma**
Executive Engineer (EMC)
NCA, INDORE

Handwritten: To chait Kanching
J. E. (Elect.)
EMC, NCA

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-1 lines are in service.

2. SCO Mode Detail:-

Nil