



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 25-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Jul-22	7:00 17:45	25-Jul-22	12:00 24:00	11:15:00	46.00	0.496 ✓	Today (i.e. 26.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	25-Jul-22	0:00:00	25-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	25-Jul-22	0:00:00	25-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	25-Jul-22	0:00:00	25-Jul-22	0:00:00	0:00:00	0.00	0.000	
5	25-Jul-22	0:00:00	25-Jul-22	2:00:00	2:00:00	41.00	0.081 ✓	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Jul-22	0:00:00	25-Jul-22	24:00:00	24:00:00	189	4.394 ✓	Today (i.e. 26.07.2022), 6 SSP-RBPB M/cs are running at 9:00 hrs.
2	25-Jul-22	0:00:00	25-Jul-22	24:00:00	24:00:00	189	4.402 ✓	
3	25-Jul-22	0:00:00	25-Jul-22	24:00:00	24:00:00	188	4.376 ✓	
4	25-Jul-22	0:00:00	25-Jul-22	24:00:00	24:00:00	189	4.446 ✓	
5	25-Jul-22	0:00:00	25-Jul-22	24:00:00	24:00:00	188	4.428 ✓	
6	25-Jul-22	0:00:00	25-Jul-22	24:00:00	24:00:00	190	4.424 ✓	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.577	26.470 ✓	27.047 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.070	184.346 ✓	199.416
PREVIOUS DAY ACTUAL RUNNING HOURS	13:15:00	144:00:00 ✓	
TODAY'S DC (Schedule) Planned (in Hours)	18:30:00	144:00:00 ✓	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00 ✓	

SSP hydrological data : at 08:00 Hrs on 26-Jul-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 128.68 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 304225 Cusec 744.31 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 46833 Cusec 114.58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3500	617

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
620	0	3495	2760	44073	252	32.50



Rajesh Sharma
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-2 lines are in service.

2. 400kV SSP-Raj-1 line is ready.

3. SCO Mode Detail:-

Nil