



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Jul-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 29-Jul-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Jul-22	0:00:00	29-Jul-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 30.07.2022), 1 SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	29-Jul-22	0:00:00	29-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	29-Jul-22	0:00:00	29-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	29-Jul-22	9:28:00	29-Jul-22	24:00:00	14:32:00	51.00	0.728	
5	29-Jul-22	0:00:00	29-Jul-22	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Jul-22	0:00:00	29-Jul-22	24:00:00	24:00:00	203	4.826	Today (i.e. 30.07.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	29-Jul-22	0:00:00	29-Jul-22	24:00:00	24:00:00	203	4.822	
3	29-Jul-22	0:00:00	29-Jul-22	24:00:00	24:00:00	202	4.824	
4	29-Jul-22	0:00:00	29-Jul-22	24:00:00	24:00:00	202	4.864	
5	29-Jul-22	0:00:00	29-Jul-22	24:00:00	24:00:00	202	4.868	
6	29-Jul-22	0:00:00	29-Jul-22	24:00:00	24:00:00	203	4.834	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.728	29.038	29.766
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	17.521	298.236	315.757
PREVIOUS DAY ACTUAL RUNNING HOURS	14:32:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC. (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Jul-22

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 131.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 75710 Cusec 185.23 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 50104 Cusec 122.58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3014	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
612	0	4678	4689	45415	296	32.50



for Abchita Kanungo
J.E (Elect.)
EMC, NCA

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil