



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 31-Jul-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	31-Jul-22	0:00:00	31-Jul-22	20:00:00	20:00:00	51.00 ✓	1.000	Today (i.e. 01.08.2022), 1 No. of SSP-CHPH M/c is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	31-Jul-22	0:00:00	31-Jul-22	0:00:00	0:00:00	0.00	0.000	
3	31-Jul-22	0:00:00	31-Jul-22	0:00:00	0:00:00	0.00	0.000	
4	31-Jul-22	6:30:00	31-Jul-22	24:00:00	17:30:00	51.00 ✓	0.868	
5	31-Jul-22	0:00:00	31-Jul-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	31-Jul-22	0:00:00	31-Jul-22	24:00:00	24:00:00	204	4.846	Today (i.e. 01.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	31-Jul-22	0:00:00	31-Jul-22	24:00:00	24:00:00	203	4.858	
3	31-Jul-22	0:00:00	31-Jul-22	24:00:00	24:00:00	203	4.862	
4	31-Jul-22	0:00:00	31-Jul-22	24:00:00	24:00:00	203	4.882	
5	31-Jul-22	0:00:00	31-Jul-22	24:00:00	24:00:00	204	4.912	
6	31-Jul-22	0:00:00	31-Jul-22	24:00:00	24:00:00	203	4.850	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.868	29.210	31.078
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	20.574	356.576	377.150
PREVIOUS DAY ACTUAL RUNNING HOURS	37:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.96 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 74450 Cusec 182.15 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 52621 Cusec 128.74 MCM ✓
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
5864	618

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	0	6635	7665	44956	268	32.50



*(Signature)*  
1/8/22  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil