



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 02-Aug-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Aug-22	18:00:00	2-Aug-22	18:15:00	0:15:00	47.00	0.013	Today (i.e. 03.08.2022), 1 No. of SSP-CHPH M/c is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	2-Aug-22	18:10:00	2-Aug-22	24:00:00	5:50:00	50.00	0.286	
3	2-Aug-22	0:00:00	2-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	51.00	1.187	
5	2-Aug-22	0:00:00	2-Aug-22	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	206	4.866	Today (i.e. 03.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	205	4.860	
3	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	203	4.842	
4	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	205	4.914	
5	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	204	4.902	
6	2-Aug-22	0:00:00	2-Aug-22	24:00:00	24:00:00	205	4.876	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.486	29.260	30.746
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	2.922	58.486	61.408
PREVIOUS DAY ACTUAL RUNNING HOURS	30:05:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.35 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 75959 Cusec 185.84 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 51644 Cusec 126.35 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6267	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
616	0	6059	6264	45380	241	32.50



*(Signature)*  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC.REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil