



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 04-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Aug-22	9:55 18:00	4-Aug-22	11:30 23:00	6:35:00	50.00	0.298	Today (i.e. 05.08.2022), 1 No. of SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	4-Aug-22	0:00:00	4-Aug-22	10:00:00	10:00:00	50.00	0.495	
3	4-Aug-22	0:00:00	4-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	4-Aug-22	0:00:00	4-Aug-22	0:00:00	0:00:00	0.00	0.000	
5	4-Aug-22	10:20:00	4-Aug-22	24:00:00	13:40:00	50.00	0.631	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Aug-22	0:00:00	4-Aug-22	24:00:00	24:00:00	204	4.848	Today (i.e. 05.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	4-Aug-22	0:00:00	4-Aug-22	24:00:00	24:00:00	203	4.848	
3	4-Aug-22	0:00:00	4-Aug-22	24:00:00	24:00:00	203	4.840	
4	4-Aug-22	0:00:00	4-Aug-22	24:00:00	24:00:00	204	4.886	
5	4-Aug-22	0:00:00	4-Aug-22	24:00:00	24:00:00	204	4.884	
6	4-Aug-22	0:00:00	4-Aug-22	24:00:00	24:00:00	203	4.838	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.424	29.144	30.568
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	5.762	116.878	122.640
PREVIOUS DAY ACTUAL RUNNING HOURS	30:15:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 49430 Cusec 120.93 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 50455 Cusec 123.44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6020	622

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	6077	5852	44603	244	32.50



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil