



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 06-Aug-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Aug-22	9:10:00	6-Aug-22	24:00:00	14:50:00	49.00	0.737	Today (i.e. 07.08.2022), 1 No. of SSP-CHPH M/cs is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	6-Aug-22	0:00:00	6-Aug-22	0:00:00	0:00:00	0.00	0.000	
3	6-Aug-22	0:00:00	6-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	6-Aug-22	6:30:00	6-Aug-22	10:00:00	3:30:00	50.00	0.178	
5	6-Aug-22	0:00:00	6-Aug-22	9:20:00	9:20:00	49.00	0.439	

**(RBPB 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Aug-22	0:00:00	6-Aug-22	24:00:00	24:00:00	204	4.832	Today (i.e. 07.08.2022), 6 SSP-RBPB M/cs are running at 9:00 hrs.
2	6-Aug-22	0:00:00	6-Aug-22	24:00:00	24:00:00	204	4.854	
3	6-Aug-22	0:00:00	6-Aug-22	24:00:00	24:00:00	204	4.840	
4	6-Aug-22	0:00:00	6-Aug-22	24:00:00	24:00:00	204	4.900	
5	6-Aug-22	0:00:00	6-Aug-22	24:00:00	24:00:00	203	4.902	
6	6-Aug-22	0:00:00	6-Aug-22	24:00:00	24:00:00	204	4.862	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUS)	1.354	29.190	30.544
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	8.613	175.280	183.893
PREVIOUS DAY ACTUAL RUNNING HOURS	27:40:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.27 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 32954 Cusec 80.62 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 50452 Cusec 123.43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6533	622

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
608	0	4532	5637	44815	242	32.50



*for*  
Archita Karungo  
S.E. (Elect.)  
EMC, NCA  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil