



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 07-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Aug-22	0:00:00	7-Aug-22	22:30:00	22:30:00	50.00 ✓	1.117	Today (i.e. 08.08.2022), 1 No. of SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	7-Aug-22	0:00:00	7-Aug-22	0:00:00	0:00:00	0.00	0.000	
3	7-Aug-22	0:00:00	7-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	7-Aug-22	0:00:00	7-Aug-22	0:00:00	0:00:00	0.00	0.000	
5	7-Aug-22	0:00:00	7-Aug-22	0:00:00	0:00:00	0.00 ✓	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Aug-22	0:00:00	7-Aug-22	24:00:00	24:00:00	203 ✓	4.834	Today (i.e. 08.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	7-Aug-22	0:00:00	7-Aug-22	24:00:00	24:00:00	204 ✓	4.864	
3	7-Aug-22	0:00:00	7-Aug-22	24:00:00	24:00:00	203 ✓	4.836	
4	7-Aug-22	0:00:00	7-Aug-22	24:00:00	24:00:00	204 ✓	4.892	
5	7-Aug-22	0:00:00	7-Aug-22	24:00:00	24:00:00	203 ✓	4.892	
6	7-Aug-22	0:00:00	7-Aug-22	24:00:00	24:00:00	204 ✓	4.862	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.117	29.180	30.297
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.730	204.460	214.190
PREVIOUS DAY ACTUAL RUNNING HOURS	22:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	19:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.27 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 48555 Cusec 118.79 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 48314 Cusec 118.20 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4532	607

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
601	0	4553	3676	44638	241	32.50



(Signature)
8/8/22
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil