



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 08-Aug-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Aug-22	0:00:00	8-Aug-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 09.08.2022), 2 No. of SSP-CHPH M/s are running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	8-Aug-22	0:00:00	8-Aug-22	0:00:00	0:00:00	0.00	0.000	
3	8-Aug-22	0:00:00	8-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	8-Aug-22	0:00:00	8-Aug-22	0:00:00	0:00:00	0.00	0.000	
5	8-Aug-22	5:00:00	8-Aug-22	24:00:00	19:00:00	50.00	0.916	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	8-Aug-22	0:00:00	8-Aug-22	24:00:00	24:00:00	204	4.838	Today (i.e. 09.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	8-Aug-22	0:00:00	8-Aug-22	24:00:00	24:00:00	204	4.866	
3	8-Aug-22	0:00:00	8-Aug-22	24:00:00	24:00:00	204	4.854	
4	8-Aug-22	0:00:00	8-Aug-22	24:00:00	24:00:00	204	4.894	
5	8-Aug-22	0:00:00	8-Aug-22	24:00:00	24:00:00	203	4.898	
6	8-Aug-22	0:00:00	8-Aug-22	24:00:00	24:00:00	204	4.862	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.916	29.212	30.128
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.646	233.672	244.318
PREVIOUS DAY ACTUAL RUNNING HOURS	19:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	27:30:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.24 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 46500 Cusec 113.77 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 50061 Cusec 122.48 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
NA	NA

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
631	0	4857	4928	45133	241	32.50



*Ashika Kamnaga*  
J.E. (E&T)  
EMC, NCA  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil