



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 11-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Aug-22	0:00:00	11-Aug-22 ✓	0:00:00	0:00:00	0.00	0.000	Today (i.e. 12.08.2022), 0 No. of SSP-CHPH M/c is running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	11-Aug-22	0:00:00	11-Aug-22 ✓	0:00:00	0:00:00	0.00	0.000	
3	11-Aug-22	0:00:00	11-Aug-22 ✓	0:00:00	0:00:00	0.00	0.000	
4	11-Aug-22	0:00:00	11-Aug-22 ✓	24:00:00	24:00:00	50.00	1.169	
5	11-Aug-22	0:00:00	11-Aug-22 ✓	0:00:00	0:00:00	0.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Aug-22	0:00:00	11-Aug-22	24:00:00	24:00:00	205	4.852 ✓	Today (i.e. 12.08.2022), 6 SSP-RBPB M/cs are running at 9:00 hrs.
2	11-Aug-22	0:00:00	11-Aug-22	24:00:00	24:00:00	205	4.856 ✓	
3	11-Aug-22	0:00:00	11-Aug-22	24:00:00	24:00:00	204	4.846 ✓	
4	11-Aug-22	0:00:00	11-Aug-22	24:00:00	24:00:00	205	4.890 ✓	
5	11-Aug-22	0:00:00	11-Aug-22	24:00:00	24:00:00	204	4.908 ✓	
6	11-Aug-22	0:00:00	11-Aug-22	24:00:00	24:00:00	205	4.862 ✓	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUS)	1.169	29.214 ✓	30.383 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	14.518	321.306 ✓	335.824 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	144:00:00 ✓	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00 ✓	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00 ✓	

SSP hydrological data : at 08:00 Hrs on 12-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.55 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 157427 Cusec 385.16 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 49470 Cusec 121.03 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5236 ✓	621 ✓

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
631	0	4586 ✓	4867 ✓	44603 ✓	253	32.50



Rajesh Sharma
12/8/22

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil