



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 12-Aug-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Aug-22	15:30:00	12-Aug-22	24:00:00	8:30:00	50.00	0.424	Today (i.e. 13.08.2022), 4 No. of SSP-CHPH M/c is running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	12-Aug-22	15:15:00	12-Aug-22	24:00:00	8:45:00	51.00	0.438	
3	12-Aug-22	0:00:00	12-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	12-Aug-22	0:00:18:45	12-Aug-22	8:00:24:00	13:15:00	50.00	0.659	
5	12-Aug-22	15:00:00	12-Aug-22	24:00:00	9:00:00	51.00	0.431	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Aug-22	0:00:00	12-Aug-22	24:00:00	24:00:00	206	4.884	Today (i.e. 13.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	12-Aug-22	0:00:00	12-Aug-22	24:00:00	24:00:00	206	4.892	
3	12-Aug-22	0:00:00	12-Aug-22	24:00:00	24:00:00	204	4.876	
4	12-Aug-22	0:00:00	12-Aug-22	24:00:00	24:00:00	206	4.916	
5	12-Aug-22	0:00:00	12-Aug-22	24:00:00	24:00:00	205	4.928	
6	12-Aug-22	0:00:00	12-Aug-22	24:00:00	24:00:00	206	4.888	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.952	29.384	31.336
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	16.470	350.690	367.160
PREVIOUS DAY ACTUAL RUNNING HOURS	39:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 160580 Cusec 392.87 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 64017 Cusec 156.62 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4585	631

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
624	8208	13442	11065	44744	265	32.50



*Aoun*  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE  
JE/EMC, NCA

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil