



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 14-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 13-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	51.00	1.186	Today (i.e. 14.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	50.00	1.196	
3	13-Aug-22	0:00:00	13-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	51.00	1.183	
5	13-Aug-22	6:30:00	13-Aug-22	24:00:00	17:30:00	50.00	0.835	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	205	4.868	Today (i.e. 14.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	204	4.878	
3	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	203	4.872	
4	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	205	4.902	
5	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	205	4.936	
6	13-Aug-22	0:00:00	13-Aug-22	24:00:00	24:00:00	205	4.880	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.400	29.336	33.736
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	20.870	380.026	400.896
PREVIOUS DAY ACTUAL RUNNING HOURS	89:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.82 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 146263 Cusec 357.84 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 81366 Cusec 199.07 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13441	624

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
610	19000	19857	18505	43861	274	32.50



JOS
Rajesh Sharma
14/08/22

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

J.E. (Eled)
EMC, NCA

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil