



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 15-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	50.00	1.207	Today (i.e. 16.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	51.00	1.202	
3	15-Aug-22	0:00:00	15-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	51.00	1.181	
5	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	51.00	1.156	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	205	4.818	Today (i.e. 16.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	205	4.818	
3	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	205	4.862	
4	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	204	4.856	
5	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	205	4.910	
6	15-Aug-22	0:00:00	15-Aug-22	24:00:00	24:00:00	205	4.844	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.746	29.108	33.854
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	30.316	438.414	468.730
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.96 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 133543 Cusec 326.72 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 176340 Cusec 431.43 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
19687	607

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
610	112708	18150	18288	45344	283	36.00



Rajesh Sharma
16/8/22
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hvdromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE (E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Detail:-

Nil