



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 17-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 16-Aug-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Aug-22	00:00 19:00	16-Aug-22	14:45 24:00	19:45:00	50.00 ✓	0.980	Today (i.e. 17.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	50.00 ✓	1.202	
3	16-Aug-22	0:00:00	16-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	51.00	1.175	
5	16-Aug-22	00:00 19:15	16-Aug-22	14:30 24:00	19:15:00	49.00	0.908	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	201 ✓	4.744	Today (i.e. 17.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	201 ✓	4.738	
3	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	202 ✓	4.752	
4	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	202 ✓	4.778	
5	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	201 ✓	4.772	
6	16-Aug-22	0:00:00	16-Aug-22	24:00:00	24:00:00	202 ✓	4.750	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.265 ✓	28.534	32.799
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	34.581	466.948	501.529
PREVIOUS DAY ACTUAL RUNNING HOURS	87:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	91:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 17-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.32 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 406441 Cusec 994.39 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 487259 Cusec 1192.11 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18150	610

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
613	427083	16606	15714	44462	276	38.00



*(Signature)*  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil