



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 19-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	51.00	1.209	Today (i.e. 20.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	50.00	1.202	
3	19-Aug-22	0:00:00	19-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	52.00	1.177	
5	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	50.00	1.129	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	206	4.782	Today (i.e. 20.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs.
2	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	206	4.798	
3	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	205	4.796	
4	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	206	4.840	
5	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	206	4.832	
6	19-Aug-22	0:00:00	19-Aug-22	24:00:00	24:00:00	206	4.802	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.717	28.850	33.567
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	48.483	551.630	600.113
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.94 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 255217 Cusec 624.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 194107 Cusec 474.90 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18357	616

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
613	131250	18298	17866	44991	291	40.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Tausy A. J. 20/08/22
JE(EMC)