



નર્મદા નિયંત્રણ અધિકારી  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-Aug-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 21-Aug-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	51.00	1.220	Today (i.e. 22.08.2022), 4 No. of SSP-CHPH M/c's are running at 9:00 hrs.  CHPH Unit no. 3 is under COH from 01.04.2022.
2	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	51.00	1.207	
3	21-Aug-22	0:00:00	21-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	51.00	1.173	
5	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	48.00	1.129	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	205	4.870	Today (i.e. 22.08.2022), 6 SSP-RBPH M/c's are running at 9:00 hrs.
2	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	205	4.880	
3	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	205	4.880	
4	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	205	4.910	
5	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	205	4.934	
6	21-Aug-22	0:00:00	21-Aug-22	24:00:00	24:00:00	205	4.874	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.729	29.348	34.077
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	57.971	610.338	668.309
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY's DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 22-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres: 136.00 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs): 185142 Cusec, 452.96 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs): 162041 Cusec, 396.45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17482	614

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	100000	17511	17933	44108	294	35.00

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

For  
Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE  
J.E. (Elect.)  
EMC, NCA