



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 24-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	51.00	1.213	Today (i.e. 25.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	50.00	1.200	
3	24-Aug-22	0:00:00	24-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	52.00	1.207	
5	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	49.00	1.136	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	199	4.712	Today (i.e. 25.08.2022), 5 SSP-RBPH M/cs are running at 9:00 hrs SSP-RBPH Unit No. 5 under emergency outage (stopped at 08:00 hrs) from 08:00 to 14:00 hrs dt 25.08.2022 for attending oil level check G/M Lower guide bearing .
2	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	199	4.692	
3	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	199	4.676	
4	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	199	4.736	
5	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	200	4.724	
6	24-Aug-22	0:00:00	24-Aug-22	24:00:00	24:00:00	199	4.714	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.756	28.254	33.010
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	72.173	696.186	768.359
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 25-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.09 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 609267 Cusec 1490.62 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 583630 Cusec 1427.89 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17361	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
610	520833	17637	18053	44744	295	40.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC AREA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil