



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 25-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	52.00	1.210	Today (i.e. 26.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	51.00	1.207	
3	25-Aug-22	0:00:00	25-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	52.00	1.195	
5	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	50.00	1.156	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	202	4.772	Today (i.e. 26.08.2022), 5 SSP-RBPH M/cs are running at 9:00 hrs
2	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	201	4.768	
3	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	201	4.754	
4	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	202	4.800	
5	25-Aug-22	00:00 10:30	25-Aug-22	08:00 24:00	21:30:00	200	4.294	
6	25-Aug-22	0:00:00	25-Aug-22	24:00:00	24:00:00	202	4.776	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.768	28.164	32.932
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	76.941	724.350	801.291
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	141:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.27 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 506201 Cusec 1238.46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 483094 Cusec 1181.92 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17637	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
609	420833	17564	18066	44195	298	40.00



for Sharma
26/8/22
J.E, EMC, NCA

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil