



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 29-Aug-22

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 52.00 | 1.217 | Today (i.e. 30.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022. |
| 2 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 50.00 | 1.192 | |
| 3 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 52.00 | 1.227 | |
| 5 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 50.00 | 1.152 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 207 | 4.904 | Today (i.e. 30.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs |
| 2 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 206 | 4.916 | |
| 3 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 206 | 4.906 | |
| 4 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 207 | 4.950 | |
| 5 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 206 | 4.962 | |
| 6 | 29-Aug-22 | 0:00:00 | 29-Aug-22 | 24:00:00 | 24:00:00 | 206 | 4.918 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 4.788 | 29.556 | 34.344 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 96.079 | 842.184 | 938.263 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 96:00:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 30-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.70 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 81605 Cusec 199.65 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 81299 Cusec 198.90 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 17366 | 610 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | RBPH TRC |
|---------|-----------|-------|-------|-------|----------|----------|
| 608 | 20000 | 17511 | 17897 | 43402 | 306 | 33.00 |



*for Archita Karmange
S.E. (Electrical)
EMC/NCA*
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil