



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY
DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 31-Aug-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 30-Aug-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	51.00	1.216	Today (i.e. 31.08.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	50.00	1.204	
3	30-Aug-22	0:00:00	30-Aug-22	0:00:00	0:00:00	0.00	0.000	
4	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	52.00	1.218	
5	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	50.00	1.145	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	207	4.912	Today (i.e. 31.08.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	207	4.930	
3	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	206	4.908	
4	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	207	4.952	
5	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	206	4.958	
6	30-Aug-22	0:00:00	30-Aug-22	24:00:00	24:00:00	207	4.916	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.783	29.576	34.359
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	100.862	871.760	972.622
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Aug-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.69 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 80174 Cusec 196.15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 81135 Cusec 198.50 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17511	608

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	20000	17366	17874	43261	306	33.00



*for Abchita Kawange
J-E (Elect)
EMC, NCA.*

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil