



નર્મદા નિયંત્રણ પ્રાધિકારણ
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Sep-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 01-Sep-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	51.00	1.219	Today (i.e. 02.09.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	50.00	1.202	
3	1-Sep-22	0:00:00	1-Sep-22	0:00:00	0:00:00	0.00	0.000	
4	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	51.00	1.206	
5	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	50.00	1.145	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	206	4.910	Today (i.e. 02.09.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	206	4.922	
3	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	206	4.890	
4	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	206	4.946	
5	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	206	4.948	
6	1-Sep-22	0:00:00	1-Sep-22	24:00:00	24:00:00	206	4.918	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.772	29.534	34.306
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.772	29.534	34.306
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Sep-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 102227 Cusec 250.11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 76396 Cusec 186.91 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17155	616

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	15416	17155	17754	43226	488	33.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil