



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Sep-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 02-Sep-22

**(CHPH 5X50 MW)**

| Unit No. | START    |         | STOP     |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS   |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 51.00          | 1.221             | Today (i.e. 03.09.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.<br><br>CHPH Unit no. 3 is under COH from 01.04.2022. |
| 2        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 51.00          | 1.201             |   |
| 3        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |
| 4        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 51.00          | 1.200             |   |
| 5        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 50.00          | 1.150             |   |

**(RBPH 6X200 MW)**

| Unit No. | START    |         | STOP     |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS  |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 206            | 4.910             | Today (i.e. 03.09.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs |
| 2        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 206            | 4.912             |  |
| 3        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 206            | 4.900             |  |
| 4        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 206            | 4.942             |  |
| 5        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 205            | 4.944             |  |
| 6        | 2-Sep-22 | 0:00:00 | 2-Sep-22 | 24:00:00 | 24:00:00    | 206            | 4.912             |  |

|  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs)                 | 4.772           | 29.520          | 34.292         |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 9.544           | 59.054          | 68.598         |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 96:00:00        | 144:00:00       |                |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00        | 144:00:00       |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 96:00:00        | 144:00:00       |                |

SSP hydrological data : at 08:00 Hrs on 3-Sep-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 81473 Cusec 199.33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 62983 Cusec 154.09 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR    | GODBOLE |
|-------|---------|
| 17155 | 617     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR    | CHPH  | RBPH  | Ev. Loss | RBPH TRC |
|---------|-----------|-------|-------|-------|----------|----------|
| 613     | 2000      | 17155 | 17722 | 43261 | 491      | 33.00    |



*(Signature)*  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil